

**A.P.STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT  
Y.S.R. DISTRICT, KADAPA.**

From,

S. Srinivasa Rao,  
District Fire Officer,  
Y.S.R. District, Kadapa.

To,

The Deputy Commissioner,  
K.V. Sangthan,  
Hyderabad.

**Re. No. 3323/A2/2017, Dated: 18.09.2017.**

Sir,

Sub:- A.P. State Disaster Response & Fire Services Department - Southern Region - Y.S.R. District - Kadapa Fire Station - Kendriya Vidyalaya, D. No. 85/412-22, Near New RIMS, Putlampalli, Kadapa, Y.S.R. District - No Objection Certificate for Occupancy - Issued - Reg.

- Ref:-
- 1) Section 13(2) of A.P. Fire Services Act, 1999 and Rule 15(2) of A.P. Fire and Emergency Operations and Levy of Fee Rules, 2006.
  - 2) Chief Office Circular Memo Rc.No.3350/Audit/NOC/2012, Dt: 09.03.2017.
  - 3) Application of the Principal, Kendriya Vidyalaya, D. No. 85/412-22, Near New RIMS, Putlampalli, Kadapa, Y.S.R. District, Dated: 19.08.2017.
  - 4) Rc. No. 212/SFO/KDP/2017, dated 12.09.2017 of the Non Multi Storeyed Building Inspection Committee, Y.S.R. District, Kadapa.
- \* \* \*

Vide reference 3rd cited, the Management of Kendriya Vidyalaya, D. No. 85/412-22, Near New RIMS, Putlampalli, Kadapa, Y.S.R. District has reported that an Educational Building was constructed without obtaining Provisional No Objection Certificate from this Department and requested for issuance of No Objection Certificate for occupancy.

2. Vide reference 4th cited, the Assistant District Fire Officer, Y.S.R. District, Kadapa and the Station Fire Officer, Kadapa have inspected the existing educational building on 12.09.2017 and recommended for issue of No Objection Certificate for occupancy to the above Educational Building.

3. Particulars of the Building :-

a) Address of the building	:	Kendriya Vidyalaya, D. No. 85/412-22, Near NEW RIMS, Putlampalli, Kadapa, Y.S.R.District.
b) Area of plot/Height of the building	:	10.00 Acers. / 07.00 Mts.
c) Total plinth area	:	4116.00 Sq. Mts.
d) No. of blocks / Floors	:	One Block / Ground + First Floor.
e) Type of Occupancy	:	Educational.

4. Open Spaces

Direction	Required as per G.O.Ms.No.119, Table No. 17.	Provided	Deficit
North (Front)	03.00 Mts.	03.00 Mts.	Nil
East	05.00 Mts.	05.00 Mts.	Nil
South	05.00 Mts.	05.00 Mts.	Nil
West	05.00 Mts.	05.00 Mts.	Nil

5. Floor wise particulars:

Sl. No.	Floors	Built-up area	Type of occupancy	Occupant load as per NBC 2016.
01	Ground	2578.00 Sq. Mts.	Educational	644
02	First	1538.00 Sq. Mts.	Educational	384
	<b>Total</b>	<b>4116.00 Sq. Mts.</b>	--	<b>1028</b>

::2::

94-  
29/09/2017  
प्रचार्य / Principal  
केन्द्रीय विद्यालय / Kendriya Vidyalaya  
कडपा / Kadapa-516002.  
आन्ध्र प्रदेश / Andhra Pradesh

6. Means of Escape :

Sl. No.	No. of Staircases	Required as per NBC 2016	Provided	Deficit
1	Internal	01.50 Mts.	02 X 01.00 = 02.00 Mts.	Nil
2	External	01.25 Mts.	02 X 01.00 = 02.00 Mts.	Nil
Total:		02.75 Mts.	04.00 Mts.	Nil

Floor Details.	No. of Occupants.	Required as per NBC 2016	Provided	Deficit
Ground	644	Required Doors.	Provided (Doors)	Nil
First	384	03.84 Mts.	04.00 Mts.	Nil

7. The management has provided Fire Safety Measures as per NBC 2016:

Sl. No.	Fire Safety Measures	Required as per NBC 2016	Provided	Deficiency
01	Fire Extinguishers	41 Nos.	41 Nos.	Nil
02	Fire Buckets	41 Nos.	41 Nos.	Nil
03	Hose Reels	04 Nos.	04 Nos.	Nil
04	Terrace Tank	15,000 Lts.	15,000 Lts.	Nil
05	Booster Pump 450 LPM	01 No.	01 No.	Nil


8. The management has remitted Fire precaution fee of Rs. 45,276/- (Rs. 41,160/- + Rs. 4,116/-) (Rupees Forty Five Thousand One Hundred and Sixty Only.) vide challan Nos. 14815 & 14826, Dt: 19.08.2017 at Sub Treasury, Kadapa.

9. The Fire Safety Systems were tested by the Assistant District Fire Officer, Y.S.R. District, Kadapa and the Station Fire Officer, Kadapa during their Inspection and found their performance satisfactory. Hence, No Objection Certificate for Occupancy to the existing Educational Building of Kendriya Vidyalaya, D. No. 85/412-22, Near New RIMS, Putlampalli, Kadapa, Y.S.R. District, is issued subject to the following conditions:-

i	All the Fire protection arrangements shall be maintained in good condition as seen during the inspection.
ii	All the escape / exit routes shall not be kept locked / blocked or encroached.
iii	All the occupants must know the correct method of operating the fire fighting equipment installed.
iv	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v	All students / staff members of the Institution shall be trained to operate the fire safety equipment during emergency.
vi	Addition / alteration, if any, in the building may be obtained with prior permission from this Department
vii	Mock drill should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

10) This No Objection Certificate for Occupancy is valid for a period of one year from date of issue. The management shall submit the application for Renewal of No Objection Certificate, two (02) months before the date on which NOC is due.

Yours faithfully,



  
 District Fire Officer,  
 A.P.S.D.R. & Fire Services,  
 Y.S.R. District, Kadapa.

(4/5)

Copy to the Management of Kendriya Vidyalaya, D. No. 85/412-22, Near New RIMS, Putlampalli, Kadapa, Y.S.R. District.  
 Copy to the Assistant District Fire Officer, Y.S.R. District, Kadapa.  
 Copy to the Station Fire Officer, Kadapa.

*Attested*

9/11/2017  
 प्राचार्य / Principal  
 केंद्रीय विद्यालय / Kendriya Vidyalaya  
 कडपा / Kadapa-516000  
 आन्ध्र प्रदेश / Andhra Pradesh  
 कडपा / Kadapa-516 001  
 आन्ध्र प्रदेश / Andhra Pradesh

  
 19/8/17  
  
 18/8/17  
 Assistant District Fire Officer,  
 Y.S.R. District, Kadapa.